



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

## ADDENDUM 2

To: All Interested Proposers

From: Claudia Sepulveda, Bid Clerk/Buyer

Date: August 9, 2006

Subject: Bid# 06-051, Bridge Replacement at the Ascarate Golf Course

---

The Purchasing Department received questions relating to the above referenced proposal. The Road and Bridge Department has responded to the following questions:

1. Can we get a set of blueprints to be able to bid on your job of the bridge replacement on Ascarate Golf Course?

**This is a design and build project, therefore blueprints are not available.**

2. The note in section 10.0 Bearing Devices indicates that the step height (from bottom of bearing to top of deck) shall be determined by the bridge manufacturer. The back wall height on a 175 structure can get rather deep. Are there any depth limitations for the back wall height at all?

**Yes, it should be between 2.5' and 3"**