



El Paso County Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 1

To: All Interested Proposers

From: Claudia Sepulveda, Bid Clerk/Buyer

Date: July 26, 2006

Subject: Bid #06-052 Fire Alarm System Upgrade for the Sheriff's Detention Facility

The Purchasing Department received questions relating to the above referenced proposal. The Sheriff's Office has responded to the following questions:

1. Is the upgrade to include an entirely new fire alarm system?

No, the contractor shall submit a bid for the upgrade of the control panels, head end equipment, of the existing Notifier Fire Alarm System.

2. If not, is the upgrade to include a new fire alarm panel and graphic annunciators?

The contractor shall replace the control panels, head end equipment, of the existing Notifier Fire Alarm System. A graphic display shall indicate the location of the reporting fire alarm device on a facility floor plan.

3. Is the upgrade to include new devices throughout the facility (smoke detectors, etc.)?

No, all existing Notifier devices such as Monitor and Control Modules, Smoke, Heat and Duct Detectors, shall not be disturbed and shall be maintained as integral parts of the upgraded system.

4. Is the upgrade to include only certain areas of the facility, and if so are all of the new devices to be connected to the existing fire alarm panel?

The upgrade will require work throughout the facility. Note that 2 workstations are required. Please see the list of equipment that the contractor must supply. (Page 7, Bid#06-053) All new equipment will be integral parts of the existing system. The contractor shall upgrade the existing system, providing a complete modern system, in working order, without any faults or deficiencies.