



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

**ADDENDUM 2**

**To: All Interested Proposers**

**From: Lucy Balderama, Inventory Bid Technician**

**Date: April 10, 2008**

**Subject: BID # 08-037, (BID) Emergency Generator for the MDR**

---

**The Purchasing Department received questions relating to the above referenced proposal during the walk through; the response to the following questions:**

1. Could we have a site visit for installations reason?  
Yes. Site visit or "walk through" may be scheduled with 24 hours notice by contacting the Facilities Management Department at 546-2009.
2. Is there an existing generator that needs to be removed?  
There is no existing generator to this facility.
3. The specifications call for a weather protective enclosure and a Nema 1 enclosure. Is the generator to be installed inside or outside?  
The generator will be installed outside on the roof of the building.
4. Is there a natural gas line in the area of installation?  
Yes. There is a gas line approximately 10 feet away on the roof where the generator will be installed.
5. If the generator is to be installed inside, is there enough ventilation and area for exhaust?  
N/A