



County of El Paso Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 1

To: All Interested Proposers

From: Lucy Balderama, Inventory Bid Technician

Date: June 21, 2008

Subject: BID # 08-103, BID Two Ray Pak Boilers & Two 534 Gallon Hot Water Storage Tanks and four (4) 115 gallon hot water storage tanks for the Jail Annex.

The Purchasing Department received questions relating to the above referenced proposal in the Pre-bidders meeting on July 21, 2008 at 10:00; the response to the following question:

1. What are the BTU inputs of these two water boilers?

627,000 BTU

2. That is the current size?

Yes.

3. Has there been an expansion?

It will be the same, 627,000 BTU

The Purchasing Department received questions relating to the above referenced proposal; the response to the following question:

1. What will the operating temperature of the boiler be?

130 to 160 degrees Fahrenheit

2. **Are there any space limitation?**

Yes

4. **Who can I contact to take a walk through of the area where work is to be done?**

Ruben Villa (915) 856-4890

Please insert the following page after page 5 as an addition to the specifications for this bid.

Pricing Sheet

2 Water Heaters with circulating pumps and 4 insulated hot water storage tanks

Price each \$ _____ Total for 2 \$ _____

4 insulated 115 gallon storage tanks to include new shut off valves, temperature gauges, operators and controllers.

Price each \$ _____ Total for 4 \$ _____

2ea. 534 gallon Hot Water Storage Tanks with new shut off valves, Temperature gauges, operators and controllers.

Price each \$ _____ Total for 2 \$ _____

Warranty:

- 1 – year for parts and labor on installation
- 5 – years for heat exchanger on boiler
- 5 – years limited warranty on storage tanks

Cost for Warranty \$ _____

Total Cost \$ _____

Contractor to remove old equipment, install new equipment and haul away all the old equipment and debris from the job site. Include in Total Cost. _____