



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 2

To: All Interested Proposers

From: Linda Mena, Inventory Bid Technician

Date: August 3, 2009

Subject: Bid # 09-070, Furnish and Install Security Equipment for Five (5) of Justice of the Peace Locations

The Purchasing Department received questions relating to the above referenced proposal; the response to the following question:

1. Is camera wiring Cat 5/ Coax/ what?
Wiring can be either Cat 5 or Coaxial cable, as required by your specified equipment. Justice of the Peace #5 is already pre-wired with Cat 5.
2. Is cable plenum rated or non-plenum rated?
Only Justice of the Peace #1 will require plenum rated wiring. The others can be wired with non-plenum rated wiring.
3. What type of power supply would be needed for this bid?
The power supply must be compatible with specified equipment, and must be part of the bid, and supplied by the bidder as part of their equipment.
4. I see no price line for material and installation should the bidder provide one?
Not necessary. Please see section D under Project Information. The scope of the work is to supply all labor and materials for all five Justice of the Peace locations.