



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 3

To: All Interested Proposers

From: Lucy Balderama, Inventory Bid Technician

Date: August 2, 2010

Subject: BID # 10-046, BID - Bosque Bonito Units 1 & 2 Subdivisions Sewer Yardline Connections

Please note the following changes:

- **Bid opening has been extended to August 11, 2010 at 2:00**

The Purchasing Department received questions relating to the above referenced Bid; the response to the following questions:

1. The owner is only paying for one (1) septic tank to be decommissioned per household, who is responsible if the household has more than one?

The Homeowner will be responsible for any additional decommissioning.

2. If the contractor is responsible will this be extra for the contractor?

It is the homeowner responsibility not the contractor. Contractor is to decommission 1 tank.

3. On sheet C4.1 of the plans you show a 4" P-trap detail for mobile homes, it call to install only when required, for bidding purposes how or when will you know is required?

If the mobile home doesn't have a P-Trap then its required to install one otherwise they don't need to do so.

4. What's the Engineers estimate for this project.

No estimate for this project. It is private property.

5. Pay item #2 says 37ea. And Pay item #3 says 70ea. With a Total of 107ea. Services
If you count on the plans there is a Total of 115ea. Services. Which one is correct?

The correct number is 107.