



County of El Paso Purchasing Department  
800 E. Overland Room 300  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

## ADDENDUM 2

**To:** All Interested Proposers  
**From:** Linda Mena, Inventory Bid Technician  
**Date:** September 29, 2010  
**Subject:** Bid 10-069, Concrete Slab, Electric, Gas for the Incinerator

---

The Purchasing Department received questions relating to the above referenced bid; below are the responses to the following questions:

1. Is there any fire protection (sprinkler system) required for the building?  
**Answer- No**
2. Will the contractor be required to provide and install a new water heater for the building?  
**Answer-Yes**
3. If the propane option is chosen, who will be responsible for paying the tank connection, rent, and fills?  
**Answer-**  
**A vendor will be contracted by the county**  
**If propane is used, a vaporizer will be needed in addition to tank**
4. What type of roof is required? Is it metal, wood, bar joists, deck, etc? If possible provide details on required roof  
**Answer-To match what the existing building has in place**
5. Is any type of insulation required for walls or roof?  
**Answer-No**
6. What is the desired strength for the concrete slab for the incinerator?  
**Answer-**  
**As permit requires. Note: The incinerator wil not exceed 30 ppsi pressure on pad**
7. What type of foundation is required for the new office?  
**Answer-Concrete, as required by permit**