

County of El Paso Purchasing Department 800 E. Overland Room 300 El Paso, Texas 79901

(915) 546-2048 / Fax: (915) 546-8180

www.epcounty.com

ADDENDUM 1

To: All Interested Bidders

From: Lucy Balderama, Inventory Bid Technician

Date: May 1, 2015

Subject: Bid# 15-016, Purchase & Installation of APC Symmetra PX Uninterruptible Power

Supply (UPS) for the Sheriff's Department

This addendum has been issued to notify vendors of the following questions:

1. Please provide a one line power drawing showing the existing Main Electric Panel. It should include main distribution panel with breaker and wire size feeding the UPS panel in the UPS room.

Response: Please view on attachment 1 and 2 on our website at www.epcounty.com click on Bids and More, List of Bids then click on the attachments.

2. Are there load calculations for the existing UPS service panel?

Response: No

3. Is the old existing UPS a Liebert 15 KVA Model UDA63015C25RT04, existing power input 480 volt 3 phase 30 amp?

Response: Yes

4. The bid is requesting pricing for a New UPS. Will the existing UPS service panel accept the new UPS requirements? (New Estimated Requirements –The New 40-45 KVA UPS will require 480 Volt input 3 Phase 90 Amp with Scalable to 90-100 KVA will require 480 Volt 3 Phase 175 Amp)?

Response: Yes

5. Do you have drawings, if so how soon can we get them?

Response: Yes. Please view attachment 1 and 2 on our website at www.epcounty.com click on Bids and More, List of Bids then click on the attachments.

6. May we submit more that one bid?

Response: Yes.

7. Is four electronic copies of this bid required, if not will my bid be rejected if I do not submit four electronic copies.

Response: Vendors are to provide four copies in electronic format and one original.

8. Does the department have standard dock facilities, or do you require a lift gate and pallet jack or inside delivery?

Response: Yes the dept. does have dock facilities & pallet jack

9. Will there be an addendum issued for answered questions, and when will it be posted?

Response: Yes. Addendums are posted after the deadline for questions has expired and the department has answered all questions.

10. Is the County open to a Single UPS 3 phase, 208VAC, 80KVA?

Response: No

Is the County open to a parallel UPS 80KVA, 208VAC 160KVA?

Response: No

Battery Run time. What is the current requirement?

Response: The current requirement is three (3) minutes max.

Does the County have an Engine Generator that can support the UPS during an outage?

Response: Yes

14. Will the County ever get to 100 KVA?

Response: This information is unavailable.

15. Pease advise if you would like us to write a proposal.

Response: The County is soliciting a bid. Please follow the specifications and requirements in the bid.

16. May I please obtain the estimate value for the above mentioned project?

Response: This information is unavailable.

17. How can I obtain a plan holder's list if the project exceeds \$250,000?

Response: We have posted the sign in sheet for the pre-bidder conference on our web site at www.epcounty.com click on Bids & More, List of Bids. We do not have a plan holder's list.