



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 1

To: All Interested Bidders
From: Blanca Güereca, Procurement Data Analyst
Date: April 26, 2018
Subject: Bid #18-029 Replace Existing Generator and Automatic Transfer Switch at the County of El Paso Medical Examiner's Office

The Purchasing Department has received the following questions:

1. Where is the low panel for the transfer switch?

RESPONSE: The load panel is located in a separate room away from transfer switch.

2. Is a remote annunciator needed for monitoring the generator?

RESPONSE: No, a remote annunciator is not needed.

3. Does the vendor need to polish the diesel fuel?

RESPONSE: No, vendor is responsible for the removal of the diesel fuel only.

4. What will be the working hours?

RESPONSE: The working hours are Monday to Friday from 8:00 a.m. to 5:00 p.m.

5. Will a rental generator be needed?

RESPONSE: No, this generator is for emergencies only.

6. Must the new generator be the same dimensions?

RESPONSE: No, generator just needs to fit in the existing space.

7. Will the wall surrounding the generator be removed?

RESPONSE: No. The wall will not be an obstacle for this project.

8. Is the transfer switch changing to a bypass switch?

RESPONSE: No, the replacement should be the same.

9. Is the warranty that is being requested for two (2) years or five (5) years?

RESPONSE: The scope of work in the specifications state:

- **Guarantee all new equipment and systems during installation and for a two (2) year period after.**

The County is requesting a five (5) year warranty.

10. Must the warranty cover all parts, labor, and transportation?

RESPONSE: Yes.

11. Will the generator need any infrastructure upgrades?

RESPONSE: No. If infrastructure upgrades are necessary, they will be done in-house.

12. Is the age of the wiring a concern?

RESPONSE: No. If new wiring is needed, it will be done in-house.

13. Does the load center of the generator supply power to the battery charger?

RESPONSE: Yes.

14. Are new connections to the new generator part of this project

RESPONSE: Yes.

15. **NOTE:** Generator must have enclosure and be rated for outdoor use (waterproof).