



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDA 2

To: All Interested Vendors
From: Oscar Avila, Procurement Data Analyst
Date: February 28, 2020
Subject: Bid 20-017 Far East Water Tank Pipe Replacement Project

The following are corrections to the specifications:

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the time and supplementary data differ from those of the original Contract Documents, this addendum shall govern and take precedence.

Bidders are hereby notified to make any necessary adjustments in their estimates on account of this addendum. It will be construed that each Bidder's Proposal is submitted with full knowledge and understanding of all modifications and supplemental data specified herein.

Acknowledge receipt of this addendum by inserting the number in the space provided on the bid form.

Revise the construction documents as follows:

SPECIFICATIONS:

DRAWINGS:

SHEET P1.0, General Notes 6. Correct minimum pressure to 35psi.
SHEET P1.0, KEYETD NOTES, 6. Correct pressure to 120psi.
SHEET P2.1, Clarification, all pipe and fittings shall be stainless steel NSF61certified for use in potable water systems.