



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

#### ADDENDUM 1

**To:** All Interested Proposers  
**From:** Linda Gonzalez  
**Date:** August 2, 2007  
**Subject:** RFP# 07-096, Heating Boiler Exhaust Duct Repair/ Replacement for the Detention Facility

---

The Bid Opening has been extended to Thursday, August 23, 2007; Deadline for questions has been extended to August 16, 2007.

The Purchasing Department received questions relating to the above referenced Bid.

**1. Who can we contact to schedule a job site visit?**

A walk through has been schedule for Thursday, August 9, 2007 at 9:00 a.m. Please report to the Purchasing Department located at 500 E. San Antonio, room 500 to sign in from here you will be escorted to the job site.

**2. Could you please specify the type of material of the new exhaust flues? (galvanized, stainless steel, double wall, etc.)**

Double wall exhaust flues, stainless steel inner tube and galvanized outer tube on all the flues.