



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901

(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 2

To: All Interested Proposers

From: Lucy Balderama, Inventory Bid Technician

Date: April 7, 2010

Subject: BID # 10-019, Re-bid - Recreation Area Enclosures for the Jail Annex
The Purchasing Department received a question relating to the above referenced bid; the response to the following question:

1. Are there any photos of the site, that can be emailed to us? [No, but you may call for a walk through. \(915\) 856-4890 Abel Maldonado](#)
2. Are there any cut sheets that can be emailed to us from a particular manufacturer that the specifications were based upon?
[Yes. \(or equivalent\) Please see Attachments](#)
3. Is this is a rebid of bid #08-178? If so there is not a Detention Facility portion or option 1 and 2 as previously requested on that bid. This is only the Jail Annex portion of that previous bid. Correct? Being a rebid we thought there should be clarification as the recent RFP #10-019 (rebid) is not nearly as specific as what was provided in the original bid package. Can you explain this further?

[This is a re-bid. The Detention was awarded. This bid is only for the Annex as specified on the specifications. All clarifications must be requested in form of a question.](#)

4. That previous bid specified 2"x2" square tube "fence posts" placed on 8' centers as well as at the corners. The current bid (#10-019) makes no mention of this instead specifies the use of 1"x1" 16 gauge square tube throughout. Is this adequate? **Yes all fence posts and corners need to be 2"x2" square tubing and fence posts set at 8' centers**

5. The previous bid (#08-178) also mentions that because the rear of each enclosure will face up against an existing wall there would be no need to provide the mesh at those locations or any sides of the proposed enclosures that adjoined a wall. Is this consistent with the requirements for bid #10-019? **Yes, this is still consistent.**

6. The bid mentions roof panels. Are these the same 8 gauge welded wire material as the side panels and door or is it calling for a solid top panel perhaps out of 12 or 14 gauge material? **Yes, the same panels will follow for the roof.**

7. Would a rust inhibitive battleship gray shop primer paint be adequate in lieu of the semi-gloss machine gray called out? **Yes, this will be adequate.**

8. Does everything need to be welded? Can we bolt panel to panel and weld the required mesh portion of the panel? **Yes everything needs to be welded, and as far as the panels go they can be bolted together and welded as long as they are secured.**

9. The previous bid mentioned that a basketball goal had to be removed. Has this already accomplished or do we have to allow for this work in the new bid? **The basketball equipment still needs to be removed by the contractor and turned over to the maintenance section.**