

County of El Paso Purchasing Department 800 E. Overland Room 300 El Paso, Texas 79901 (915) 546-2048 / Fax: (915) 546-8180

## **ADDENDUM 4**

To: All Interested Proposers

From: Linda Mena, Inventory Bid Technician

- Date: March 3, 2011
- Subject: Bid # 11-001, Replace Floor Drains (2nd Floor) for the El Paso County Detention Facility

## **Please Note:**

The Bid opening has been schedule for Wednesday, March 16, 2011 at 2:00 p.m.

The Purchasing Department received questions relating to the above referenced Bid; the response to the following questions:

- At the site visit, some cleanouts were spotted. Do we need to remove them and/or replace them? Yes, all cleanouts and associated pipes shall be replaced.
- 2. Also, at the site visit, we saw two mop sinks that needed repair. Shall we include them in the bid?

Yes, the repair of the mop sink drains shall be included.

3. As per documents, piping shall be cast iron. Can we use PVC with fire rated insulation instead?

Yes, the contractor may use PVC pipes with approved fire rated insulation. The contractor shall follow all rules and regulations outlined in the 2009 International Plumbing Code®, Chapter 7, Sanitary Drainage, and Chapter 6, Duct Systems. For additional information regarding applicable rules and regulations, the contractor may contact Mr. Joe A. Stiles, M.E., Mechanical Engineering Associate, City of El Paso, Development Service Department, 2 Civic Center Plaza, El Paso, TX 79901-1153. (915) 541-4798