



County of El Paso Purchasing Department  
800 E. Overland Room 300  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180  
[www.epcounty.com](http://www.epcounty.com)

---

**ADDENDUM 1**

**To:** All Interested Proposers  
**From:** Blanca Carbajal, Procurement Data Analyst  
**Date:** March 22, 2017  
**Subject:** Bid #17-014 Construction of New Metal Building at Ascarate Park for Public Works Department

---

**PLEASE NOT THE FOLLOWING CHANGES:**

- ❖ Opening date has been extended to **Monday, April 10, 2017 at 2:00 p.m.**
- ❖ Deadline to questions has not been extended.

**This addendum is issued to serve as a summary of the site visit held on Wednesday, March 22, 2017:**

1. Is a density test necessary?

**RESPONSE: No.**

2. What is the elevation that should be used?

**RESPONSE: The same elevation as the existing building.**

3. This building is 15 feet high?

**RESPONSE: Yes, as per specifications.**

4. Is any electricity required?

**RESPONSE: This is a simple three sided wall building.**

5. Is spot footing required only?

**RESPONSE: Yes.**

6. Is 4' pipe required?

**RESPONSE: Yes, as per specifications.**

7. The gage for the metal is on the specifications?

**RESPONSE: Yes, submit any other questions in writing.**

8. Does the structure need to pass city inspection, are any seals required?

**RESPONSE: No.**

9. Are spot checks required?

**RESPONSE: No.**

---

**The following questions were sent to the Purchasing Department:**

1. What is the thickness or gauge of the posts and the channels?

**RESPONSE: SS40 PIPE.**

2. What is the gauge for the R-panel?

**RESPONSE: 26 gauge.**

3. How far apart are the 4" posts?

**RESPONSE: Refer back to specifications.**

4. Is an engineered set of drawings required or is any engineering stamp required at all?

**RESPONSE: Yes, the vendor is require to have engineered set of drawings.**

5. Who is responsible for permitting?

**RESPONSE: No permits are necessary.**

6. Is there a warranty requirement for any of the construction?

**RESPONSE: Yes, warranty on part labor and factory warranty on the metal.**

7. Does the vendor have to free span the 35 ft or to put center columns?

**RESPONSE: Vendor can install center columns.**

8. Is there a scale wage requirement for this project?

**RESPONSE: Yes, see specifications.**