



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

## ADDENDUM 2

To: All Interested Proposers

From: Claudia Sepulveda, Bid Clerk/Buyer

Date: August 9, 2006

Subject: Bid# 06-053, Cooling Supply Fans for the Sheriff's Detention Facility

---

The Purchasing Department received questions relating to the above referenced proposal. The Sheriff's Office has responded to the following questions:

1. What is the cfm rating of the cooling supply fans?

**The units are designed to supply 30,000 cfm. Currently, during smoke removal operations, the units move in excess of 28,000 cfm. Additional information may be obtained from the Loren Cook Company, the manufacturer of these units.**

2. What is the design static pressure for the units?

**The original design called for 1.5 inchw. At this time, the units are operating to maintain a 0.9 inchw set point.**

Notes:

Minimum requirements for cfm, air exchanges and smoke removal operations must be maintained and verified. The system performance, as documented in the Certified Adjust Test and Balance Report, issued March 27, 2006, must be maintained.