



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 3

To: All Interested Proposers
From: Lucy Balderama, Inventory Bid Technician
Date: December 8, 2015
Subject: RFP# 15-053 Upgrade Existing HVAC Pneumatic Control System with a Direct Digital Control System for the Medical Examiners

This addendum is issued to notify vendors of the following questions:

1. Will the existing controller for the hot water and chilled water plant need to be replaced with a new controller?

Response: **The existing controller for hot water and chilled water plant will be re-used.**

2. Should all of the temperature sensors and relays in the equipment room be replaced or will they be re-used?

Response: **All temperature sensors and relays in equipment room will be re-used.**

3. Will the existing boiler and chiller control panel be replaced or can it be re-used?

Response: **The existing boiler and chiller control panel will be re-used.**

Please note the statement below:

All items will be re-used if they are compatible with your controls and should be re-placed if not compatible.