



County of El Paso Purchasing Department  
800 E. Overland Room 300  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180  
[www.epcounty.com](http://www.epcounty.com)

---

**ADDENDUM 1**

To: All Interested Bidders  
From: Oscar Avila, Procurement Data Analyst  
Date: March 27, 2018  
Subject: Bid #18-018 Replace Emergency Diesel Fire Pump at the County Courthouse

---

**The following is a recap of the pre-bid conference held on Wednesday, March 21, 2018:**

1. What is the purpose for replacing the fire pump?

**RESPONSE: Existing pump is outdated. Replacement parts are unavailable. The County wants to obtain a new pump that can run off of the existing generator.**

2. What is the output voltage needed?

**RESPONSE: Motor- 480 3 Phase.**

3. Will vendor need to remove current pump?

**RESPONSE: Yes, the vendor will dispose of existing pump and any other material according to local, state, and federal regulations.**

4. Will pouring of a concrete pad for the pump be the responsibility of the vendor?

**RESPONSE: County Facilities will manage pouring of concrete and related activities should the need arise.**

5. How is the accessibility to the pump location?

**REPOSNE: The pump is located in the Lower Level of the County Courthouse. Access to a freight elevator is available. Removal of doors and/or walls necessary to accommodate for removal of existing and installation of new pump will be provided by County Facilities.**

---

**The Purchasing Department has received the following questions:**

1. Is there a cost estimate or budget available for this project?

**RESPONSE: Cost estimate or budget will not be disclosed.**