



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

### ADDENDUM 1

To: All Interested Proposers  
From: Claudia Sepulveda, Bid Clerk/Buyer  
Date: August 8, 2006  
Subject: Bid# 06-053, Cooling Supply Fans for the Sheriff's Detention Facility

---

The opening date has been extended to Tuesday, August 15, 2006 at 2:00 p.m. However, the deadline for questions has not been extended.

The Sheriff's Office has responded to the following questions:

1. Are new motor mounts required?

**Yes, the new motors shall be supplied with new motor mounts.**

2. What are the fan model and serial numbers?

**Model Number: 3303DCA-2**

**Serial Number: 127454-00 4/81**

**Note: Numbers for one unit only. The second fan is the same type and model.**

3. What are the dimensions of the elevator carts?

**Width: 63-1/2 Inches, Length: 92 Inches, Height: 84 Inches**

**Maximum Door Opening: 47 Inches**

4. What size are the door openings on the way from the inmate elevators to the supply fan units?

**Elevator Vestibule Door: 36 x 83-3/4 Inches**

**Hallway Door: 34-1/2 x 83 Inches**

**Mechanical Room Door: 34-1/2 x 78-3/4 Inches**

**Steel Access Door: 20 x 70 Inches**

**Notes:**

1. In order to gain access to the cooling supply fan, the steel enclosure, containing the access door, may be temporarily removed.
2. Prior to ordering equipment, the contractor shall thoroughly inspect the job site and verify all measurements.