



County of El Paso Purchasing Department  
500 East San Antonio, Room 500  
El Paso, Texas 79901  
(915) 546-2048 / Fax: (915) 546-8180

---

### ADDENDUM 1

**To:** All Interested Proposers  
**From:** Linda Gonzalez, Bid Clerk/Buyer  
**Date:** April 30, 2007  
**Subject:** Bid # 07-048 (Re-bid) Texas Bootstrap

---

The Purchasing Department received questions relating to the above referenced proposal.

1. Drain plumbing fittings: specifically which ones in the set? Which sizes? How many of each one in the set?
  - Baffles Tee 1 ½ " end outlet slip joint
  - End Outlet Wastes 1 ½ " x 12"
  - J-Bend Sink Trap 1 ½"
  - Strainer Tailpieces Budget Gauge 1 ½" x 12"
  - One (1) per set
2. Lavatory faucet-what material and color? What form?
  - Delta Lavatory Faucets Clear Knob Handle with Plastic Chrome
3. P Traps-with or without union?
  - With Union
4. Pipe, valves and fittings-Specifically which ones and how many in the set? Which sizes?
  - PVC – Drain 1 ¼" x 12"
  - PVC – Drain 1 ½" x 12"

- Angle Valve Stop ½" ½"
- Lavatory Sink Connectors FIP Inlet ½ " x ½" Polymer Braid

5. Tail pipes-how long?

- Some @ 1 ¼"x 12"
- Some @ 1 ½" x 12"

6. Toilet- With or without lid? Which color? Round or elongated? Regular or handicap?

- With Lid
- White
- Round
- Regular

7. On Delta products, can we substitute for a compatible product?

- No

8. What happens if I don't carry 1 or 2 items in a set, can I still bid?

- Yes

9. Do I bid on it as a set or do I specify each item?

- As a set