



County of El Paso Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 2

To: All Interested Proposers
From: Linda Gonzalez, Bid Clerk/Buyer
Date: May 4, 2007
Subject: Bid # 07-048 (Re-bid) Texas Bootstrap

The Purchasing Department received questions relating to the above referenced proposal.

1. On addendum 1 you mention end outlet wastes-do you need slip joint connect or direct connect?

- **-Direct connect**

2. On the PVC pipes and fitting is it schedule 40 or DWV?

Schedule 40

3. Drain plumbing fittings: How many feet do you need of pipes 1 ¼ and 1 ½ per set so that I can quote by set.

- **1¼ - 40'**

- **1½ - 40'**