



County of El Paso Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 4

To: All Interested Proposers
From: Lucy Balderama, Administrative Assistant
Date: June 6, 2007
Subject: Bid# 07-063, Replacement of Three Cooling Towers at the County Courthouse

The Purchasing Department received a question relating to the above referenced Bid.

1. Where can we get a set of plans for these projects? [See Attachment](#)

[To view a larger set of plans they are available at the Road & Bridge Department 4th floor room 407 or you can purchase a set for \\$4.00 nonrefundable.](#)

2. Can we bid a Marley NC Series induced cross flow tower?

[No](#)

3. What is the total gpm required for the three cooling towers? The specification states that each unit shall have the capacity to cool 4,500 gpm of water from 95F to 85F at 72F. Please clarify if the 4,500 gpm is for each cooling tower which equals a total of 13,500 gpm or if the total for all three cooling towers is 4,500 gpm.

[Yes, the capacity of each unit is 4,500 gpm.
As per performance and Mechanical specifications.](#)