



County of El Paso Purchasing Department
500 East San Antonio, Room 500
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 2

To: All Interested Proposers

From: Linda Gonzalez

Date: June 18, 2007

Subject: Bid# 07-085, Replacement of Chillers at the MDR Building

The Purchasing Department received questions relating to the above referenced Bid.

1. May we have a point of contact (name and number); person who may assist us in visiting the job site (MDR Building)

Manuel Lucero or Ruben Lopez (915)546-2009

2. What are entering water conditions?

**Depending on time of day:
67°F to 74°F**

3. What are leaving water conditions?

**Depending on time of day:
74°F to 80°F**

4. There is no glycol in this system, correct?

No

5. What fouling factor should be used for the condenser and evaporator?

That would be based on the brand and type of unit the vendor is submitting a bid for, so the vendor must reference the manufacturer's specs.

6. What thickness insulation on cold parts?

1 inch

7. What are the warranty requirements for the chillers?

There is no warranty "requirement", however bids that come in with covered warranty periods, with or without a charge, is more desirable and will factor in to the decision making process.

8. What is the minimum efficiency for these chillers?

There is no minimum efficiency for these chillers. Based on manufacturer's specifications of the brand and type of chiller that is bid, a more efficient unit is desirable and will factor in to the decision making process.

9. Could you please send us the list of attendees to the pre-bid conference for the 07-085, Replacement of Chillers at the MDR Building project?

See next page

10. Could you please send us the plan holder list for the 07-085, Replacement of Chillers at the MDR Building project?

See next page

11. What are the water flow rates?

Capacity 400 GPM 50 HD FT

12. What are the water temperatures?

Depending on time of day:
67°F to 74°F

Depending on time of day:
74°F to 80°F

