



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180

ADDENDUM 1

To: All Interested Proposers

From: Linda Mena, Inventory Bid Technician

Date: August 8, 2011

Subject: RFQ #11-030, Engineering and Environmental Services for the Colonia Revolucion Water Line Extension Project

PLEASE NOTE:

- The cut-off-date to receive sealed RFQ's for this project has been deferred to Wednesday, August 17, 2011 at 2:00 p.m. Mountain Time zone.

The Purchasing Department received a question relating to the above referenced bid; the following is the response to the question:

1. Please advice length of line and material type you prefer, if you have a preference, or is that open to conclude from several types of materials at bid time.

Please refer to page 5, under I. BACKGROUND INFORMATION on the RFP packet. This is a request for qualifications therefore; the types of materials will be determined during construction bid phase.

I. BACKGROUND INFORMATION

The Colonia Revolución Water Distribution System project consists of constructing a water main from east property line of West Texas Estates to Colonia Revolución. Approximately 8,000 linear feet of 8-inch diameter water main is needed along Pellicano Drive Extension to a proposed pumping station that will include a 50,000 gallon storage tank, a 0.46 MGD rated pumping station and a 140,000 gallon elevated storage tank. Also required is the construction of 23,500 linear feet of 8-inch diameter distribution main within the development's streets and associated valves, fire hydrant and connections to serve approximately 80 residences.