



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 2

To: All Interested Bidders
From: Lucy Balderama, Inventory Bid Technician
Date: January 6, 2014
Subject: BID# 13-069, Construction and Installation of the Lady Justice Pedestal at the El Paso County Courthouse

This addendum has been issued to notify the vendors of the following questions:

1. What is the estimated budget?

Response: Undisclosed.

2. What is the thickness of the existing slab?

Response: The thickness of the existing slab is 6.5" concrete

3. Will the offeror be responsible for installing the statue?

Response: Yes.

4. How much does the statue weigh and what are the dimensions?

Response: The Statue weighs 200 pounds and she is approximately 8-9' tall.

5. If equipment is necessary for installation, what type of equipment is permitted at the site?

Response: This is an indoor environment therefore equipment will need to pass through standard 36" double doors. There is ceramic tile area original to the building and it will break without distributed weight – great effort needs to be taken to prevent tile breakage. Being indoors, any equipment emitting fumes or exhaust will need to be properly ventilated.

6. How large of an opening is present for machinery/installation equipment to pass through?

Response: Equipment must be able to pass through standard 36" double doors. Once inside, there is no ceiling and there is considerable room to maneuver height and width.