



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 3

To: All Interested Proposers
From: Araceli Hernandez, Inventory Bid Technician
Date: January 6, 2014
Subject: BID# 13-071, Cabling Services for the New Northwest Annex Building

This addendum has been issued to notify the vendors of the following clarifications:

1. The response to questions 4 and 6 appear to be inconsistent. Response to question 4 indicates that EC will provide cable tray but, it appears that the answer to question 6 indicates that the communications contractor will provide the cable tray. These are significant dollars in this bid. Please clarify.

Response: The cable tray will be provided by the EC

2. The answer to question 32 indicates that the County will provide the floor mounted racks for the TR's.
The question asked specifically about ladder racks above the racks tying the cabling path from the TR to the cable tray and J-Hooks outside the TR's.

Response: Cabling contractor will provide paths (ladder tray) from MDF and IDFs to the cable trays.