



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDUM 3

To: All interested Bidders
From: Lucy Balderama, Procurement Data Analyst
Date: May 30, 2017
Subject: BID #17-021, Desert Acceptance (Square Dance) Wastewater Collection System

BID OPENING DATE HAS CHANGED FROM “May 31, 2017” TO “June 8, 2017”. Bids are still due at 2:00 pm local time (MST).

I. CONTRACT

A. BID OPENING:

REPLACE “May 31, 2017” with “June 8, 2017” for all Bid Opening date references throughout the Contract Documents.

II. SPECIFICATIONS:

A. SECTION 02605 MANHOLES: Page 02605-4, Article 2.03:

MODIFY specification requirement for interior coating from “...with a depth greater than **6 feet...**” to “...with a depth greater than **9 feet...**”

In addition, **ADD** the following additional Acceptable Coating:

“RAVEN 405: 100% solids epoxy, wet/dry film thickness 80 mils, per manufacturer requirements.”

B. SECTION 02610 SCHEDULE OF PIPE: Page 02610-2, Article 2.01:

ADD the following section to both 2.01.A and 2.01.B as an additional approved pipe material:

“3. High Density Polyethylene (HDPE) Pipe conforming to ASTM F2736, double wall, 46 psi minimum stiffness (tested to ASTM D2412) for all pipe up to and including 30”

diameter. Pipe and fittings shall be watertight according to the requirements of ASTM D3212. Contractor shall refer to Section 02622 Specification similar contract requirements with exception of applicable references now to HDPE material specifications as included herein.”