



County of El Paso Purchasing Department
800 E. Overland Room 300
El Paso, Texas 79901
(915) 546-2048 / Fax: (915) 546-8180
www.epcounty.com

ADDENDA 1

To: All Interested Vendors
From: Oscar Avila, Procurement Data Analyst
Date: February 27, 2020
Subject: Bid 20-017 Far East Water Tank Pipe Replacement Project

The following is a recap of the site visit:

1. Approximately how many people are being serviced in the area?

RESPONSE: Roughly 400 homes.

The following are clarifications to the specifications:

- ❖ Minimum working pressure is 35psi.
- ❖ Three negative bacteriological samples are required on the temporary system before being put in operation.
- ❖ The tie in from the temporary to existing needs to be complete and in operation in less than six hours due to on storage reasons.